

# CITY OF NEWTON, MASSACHUSETTS

## PURCHASING DEPARTMENT

[purchasing@newtonma.gov](mailto:purchasing@newtonma.gov)

Fax (617) 796-1227

November 25, 2008

## ADDENDUM #2

### INVITATION FOR BID #09-45

### BOILER REPLACEMENT AT UNDERWOOD SCHOOL

THIS ADDENDUM IS TO: Answer the following Questions:

**Q1. Does the existing piping receive insulation in addition to the new.**

**A1. Yes – all new and existing low pressure steam, condensate, and boiler feed piping receives insulation as well as new plumbing piping and that plumbing piping indicated on the drawings.**

**Q2. Will the existing 4” domestic water heater flue be connected to the new breeching?**

**A2. Yes – Relocate the existing 4” domestic water heater flue from its’ current chimney connection to the new breeching, located just prior to the chimney entry. The existing chimney connection shall be patched.**

**Q3. Is there asbestos?**

**A3. Yes – refer to Section 02080 of the contract documents.**

**Q4. Is there a door leading to the outside from the boiler room?**

**A4. Yes – there is a door from the boiler room to the outside.**

All other terms and conditions of this bid remain unchanged

**PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORM**

Thank you.

Re Cappoli

*Chief Procurement Officer*